

## FIRE SAFETY CERTIFICATE

No.134/2024

Dated: 21/03/2024

Certified that the L.P.Savani Vidhyabhavan, L.P.Savani Circle, Honey Park Road, Adajan, Surat-394510. Comprised of **One Building Block Basement, G+4** owned/occupied by L.P.Savani Vidhyabhavan, L.P.Savani Circle, Honey Park Road, Adajan, Surat-394510. (name of the Institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the officers concerned of Fire Service on **18/03/2024** (date of inspection) in the presence of **Principal Mr. Varun Narang, L.P.Savani Vidhyabhavan, L.P.Savani Circle, Honey Park Road, Adajan, Surat-394510.** and that the building/premises is fit for occupancy class I to XII with effect from **21/03/2024** for a period of **1 year** in accordance with rule and subject to compliance of the specific conditions as appended :-

1. This it should be insured that the available fire safety equipment is always in good working condition.
2. Electric wiring in the entire building shall be checked and certified by the competent authority.
3. As per Hon'ble Supreme Court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the fire safety day on April 14<sup>th</sup> of every year by conducting fire safety drills with coordinate with fire service department.

Issued on **21/03/2024** at **Surat** by

\* Strike out whichever is not applicable.



Signature with Seal: .....

Name

Designation

21/03  
I/C Chief Fire Office  
Fire & Emergency Department  
Surat Municipal Corporation

Name & Address of Department/ Office : .....